

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ · ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1130226

Product: Surge Protective Device

Type: HS50-50, HS100, JK110 (see enclosure)

Rating: Uc 255 V AC, I imp 50, 100, 110 kA

Ordering firm: HAKEL spol. s r. o.
Bratři Štefanů 980, 500 03 Hradec Králové, Slezské Předměstí, Czech Republic

Manufacturer: HAKEL spol. s r. o.
Bratři Štefanů 980, 500 03 Hradec Králové, Slezské Předměstí, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 202020-01/01 of: 27.09.2012

A sample of the product was found to be in conformity with:

ČSN EN 61643-11:03+A11:07

cl. 6.1.1, 6.1.2, 6.2.1, 6.3.1, 6.3.2, 6.4, 6.5.1, 7.2.2, 7.3.2.1, 7.3.2.2.1, 7.3.2.2.2, 7.4.1, 7.9.2, 7.9.3, 7.9.4, 7.9.5.2, 7.9.7, 7.9.8, 7.9.9

The validity of the certificate is limited to: 31.3.2016

4.4.2013

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



* C E R / 1 1 3 0 2 2 6 *

202020-01

Surge Protective Device

Markings	Cat. No.	I_{imp} (kA)	U_c (V)	U_p (kV)
HS50-50	10 090	50	255	< 1,3 kV
HS100	10 100	100	255	< 2 kV
JK110	10 110	110	255	< 2 kV

